

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 4
2. AMENDMENT/MODIFICATION NUMBER 0002	3. EFFECTIVE DATE 03/09/2026	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER (If applicable)	
6. ISSUED BY NAVFACSYS COM MID-ATLANTIC PWD LITTLE CREEK FACILITIES ENGINEERING & ACQ DIV 1450 GATOR BLVD SUITE 150 VIRGINIA BEACH VA 23459-8616	CODE	7. ADMINISTERED BY (If other than Item 6)		CODE
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NUMBER N4008526R0085
			(X)	9B. DATED (SEE ITEM 11) 02/12/2026
				10A. MODIFICATION OF CONTRACT/ORDER NUMBER
				10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended. is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.**

CHECK ONE <input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

LC-3841/3842 MODERNIZE MEDICAL SPACES, JEBLCFS, VIRGINIA BEACH, VA

Proposal due date has been extended to Thursday, 26 March 2026 @ 1400 hours.

The purpose of this amendment is to provide: (1) Proposal extension date, (2) PPI responses

SEE SF 30 BLOCK 14 CONTINUATION PAGE

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA
16C. DATE SIGNED			
<hr/> (Signature of person authorized to sign)		<hr/> (Signature of Contracting Officer)	

PPI No.	Date Submitted	REFERENCE			QUESTION	GOVERNMENT RESPONSE	Amend No.
		Page	Section	Para.			
1	2/16/2026				<p>Tazewell Contracting respectfully requests consideration of a three-week extension to the current proposal due date for Solicitation N4008526R0085 LC-3841/3842-Modernize Medical Spaces.</p> <p>Due to a previously scheduled medical procedure impacting key personnel involved in the preparation of this submission, additional time would allow us to finalize a thorough, well-coordinated, and fully compliant proposal. We believe a short extension would support the submission of the highest quality proposals in the Government's best interest.</p> <p>We remain very interested in this opportunity and fully committed to delivering a competitive and responsive submission.</p> <p>Thank you for your consideration. Please let us know if any further information is needed</p>	The due date for proposals has been extended to March 26, 2026	0002
2	2/17/2026				<p>Drawing G-001 mentions that the contractor will be able to work the 2 buildings simultaneously. Will each space be completely vacated by the commands?</p>	Yes	0002
3	2/17/2026	11	01 50 00	3.5	Will a construction trailer be necessary for this project?	No	0002
4	2/23/2026				What is the deck height in both buildings where the work is to occur?	First fl = 15'-4" to top of second floor. Second fl = 15'-0" to underside of decking.	0002
5	2/23/2026				<p>In BLDG 3842 - RM 204, and BLDG 3841 - RM 223, per plan page A-101, not all of the walls around the rooms are getting security mesh. Normally, all surrounding GWB walls would get security mesh to create a secure space. Could the government clarify if all new AND existing walls in these rooms should get security mesh, or just the new wall partitions?</p>	No, only the walls indicated will receive the mesh.	0002
6	2/26/2026				<p>Drawings ED101 and E-101 do not show existing panel LC2 for BLDG3841 RM 221 while Drawing E-102 for BLDG3841 shows panel LC2 in RM 221. Drawing E-502 also shows the existing panel LC2 schedule. Will a new panel be required for this project? If so, please provide details of the requirements.</p>	Panel LC2 is existing, no new panel is required.	0002

7	2/26/2026			Drawing ED101 states: Demolish ESS Devices, Reprogram System as Required. Which company is authorized to reprogram the ESS system?	The Activity owns and operates the access control portion of the ESS. The Activity will remove the access control ESS devices and reprogram the system. Demolish access control ESS back boxes, pathways, patch and paint by the Contractor.	0002
8	2/26/2026			Drawing E-102 specifies: Provide 48-port patch panels in existing NIPR & SIPR racks in RM A203B and B203. Please provide the manufacturer and model number of the existing patch panels.	Existing patch panels are manufactured by Leviton	0002
9	2/26/2026			Drawing E-001 states that the existing cable tray may be utilized where available. Please provide a diagram of the existing cable tray route from RM A203B and B203 in relation to the areas of new work.	For bidding purposes, the entire run shall be supported by J-hooks. After award and Contractor inspection confirms cable tray location/capacity, coordinate proposed use of cable tray with COR	0002
10	2/26/2026			Will the testing required in specifications DIV 26 require a third party?	No	0002
11	2/26/2026			Will the testing required in specifications DIV 27 require a third party?	No	0002
12	2/26/2026			Specification calls for listed sealant around electrical penetrations. Please provide the requirements for the listed sealing material.	The sealant is to minimize air and sound transmission between spaces. The listed sealant shall be acceptable for use with electrical and telecommunications. The sealant shall also be fire-rated where required.	0002
13	2/26/2026			Please confirm that rigid conduit with welded fittings are not required for SIPR and S-VOIP cabling.	The majority of the building is a secure area, penetrations within the project area do not have PDS requirements	0002
14	2/26/2026			Please provide a location for the nearest isolation valves for plumbing additions in both buildings. If closing this valve impacts service beyond areas identified for renovation, would all work related to plumbing additions in BLDGs 3841 and 3842 be required to occur off-hours?	Field verify exact locations of isolation valves, If closing this valve impacts service beyond areas identified for renovation, coordinate with building occupants ahead of time.	0002
15	2/26/2026			Does the project provide new thermostats or relocate existing thermostats in BLDGs 3841 and 3842?	Existing thermostats to remain	0002
16	2/26/2026			Div23 specs note an Appendix D for Duct Air Leak Testing (DALT). We were unable to locate an Appendix D in the specs. Please confirm that DALT testing is a project requirement.	DALT testing is not required.	0002
17	2/26/2026			Please confirm the project scope does not impact existing fire alarm and/or mass notification devices.	Relocate horn/strobe on wall to be demolished, refer to sketch. Disconnect horn/strobe and demolish associated conduit and wire to nearest junction. Retain existing horn/strobe and circuit for reuse. Mount relocated horn/strobe as shown on sketch, intercept and extend existing fire alarm circuit.	0002
18	2/26/2026			Can the contractor utilize existing receptacles in BLDGs 3841 and 3842 during construction? If so, is the contractor responsible for payment of utility bills?	Yes, existing receptacles may be used. No, the Gov't will provide reasonable amounts of power at no charge.	0002

19	2/26/2026				Please confirm no medical gas systems are present in the areas identified for renovation in BLDGs 3841 and 3842.	No medical gas systems are present	0002
20	2/26/2026				Please confirm access control, intrusion detection, or electronic security components identified for removal in BLDGs 3841 and 3842 are not being reinstalled/relocated as part of this contract.	Correct	0002
21	2/26/2026	1	271000		Please provide the location(s) of the telecommunications rooms.	Refer to keyplans on E-102, the estimated linear distance to A203B from RM 208 is 80 feet; to B203 from Rm 222 is 130 feet	0002
22	2/26/2026	27 10 00			During site visit LC-3841 we were unable to access electrical room to verify electrical panels and breakers. Please provide pictures of panels, panel labels and existing breaker types.	Refer to panelboard manufacturer and model number info on E-502, Panel LC2 is a Square D model NQ panelboard	0002
23	2/26/2026	27 10 00			Is hospital grade devices required or can we provide standard commercial grade devices?	Commercial grade is acceptable, Hospital grade is not required	0002
24	2/26/2026	27 10 00			Is hospital grade MC cable required or can we install regular MC cable?	Conduit and flexible conduit are required for this project	0002
25	2/26/2026	27 10 00			Please clarify the scope for the Telecomm data cabling.	Refer to E-001, ED101, E-102; includes demolition and new, outlets, cabling, supports, patch panels, testing, etc	0002